

安全评价报告信息网上公示


	项目名称	中国石化销售股份有限公司北京西城宣武门加油站经营危险化学品安全现状评价		
	行业类别	石油加工业	报告提交时间	2025.7.6
项目概况	项目简介	<p>中国石化销售股份有限公司北京西城宣武门加油站成立于1963年01月1日，位于北京市西城区宣武门东大街。该加油站类型为分公司，负责人为：陈同。该加油站许可经营范围：成品油零售。该站共有10人，其中站经理1人（张梅荣），值班经理：汪润泽，武晓惠，杨保华，专职安全管理人员1人（吴晓全）。安全生产风险等级为低风险。</p> <p>该加油站设置3座SF双层油罐，均为汽油储罐，单罐容积30m³，现设有3台汽油加油机。</p> <p>该加油站除通气管外，所有工艺管道埋地敷设。加油管道（出油管线）采用导静电的热塑性复合管道，卸油管道、卸油油气回收管道、加油油气回收管道及通气管采用无缝钢管。</p> <p>该加油站采用潜油泵式加油工艺，设有汽油加油、汽油卸油油气回收系统和油气回收处理装置。站房内设有双层管线、双层罐、防渗罐池渗漏监测系统、带有高液位报警功能的液位仪及油气回收在线监控系统。</p> <p>该加油站总储量为90m³，单罐最大容积为30m³，依据《汽车加油加气加氢站技术标准》（GB50156-2021）第3.0.9条，加油站等级划分，该加油站属于三级加油站。该加油站目前无停用装置、无在建项目、无试运行装置。</p>		
安全评价项目参与人员	项目评价组长	李百元	技术负责人	邹方永
	过程控制负责人	唐晓娟	报告编制人	李百元
	报告审核人	李茂刚	安全评价师	刘全进 张会平 臧怀壮 刘红岩
	注册安全工程师	张会平 唐晓娟 刘全进 刘红岩 李百元	技术专家及技术人员	——

评价活动主要信息	安全评价类型	安全现状评价
	到现场开展评价工作人员	李百元 刘红岩
	到现场开展评价工作时间及主要任务	2025.3.18 了解项目的基本情况、对现场进行勘验；2025.4.30 对整改情况进行了复查。
	现场照片	 <p>The top photograph shows a SINOPEC POWER gas station with a red and white canopy. The bottom photograph shows three people (two men and one woman) wearing high-visibility safety vests standing in front of a sign for the Beijing Petrochemical Company (中国石化北京石油分公司) at the Xuanwumen Station (宣武门加油站). The sign also lists the contact person, operating hours (0:00-24:00), and address (北京市西城区宣武门东).</p>









备注及其他信息

无